

0402-CPR-SC0260-15

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction products

#### Solid wood panelling and cladding

for use as external finishes in walls subject to reaction to fire regulations, with specification and performance as specified on page 2-5 in this certificate.

Product name: Woodsafe Exterior WFX

placed on the market under the name or trademark of

Woodsafe Timber Protection AB

Box 1153

SE-791 29 Västerås, Sweden

and produced in the manufacturing plant

Woodsafe Timber Protection AB, Fågelbacken, SE-725 95 Västerås, Sweden

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard

EN 14915:2013

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

#### constancy of performance of the construction product.

This certificate was first issued on 2015-07-10 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Issued by notified body 0402.

The validity of this certificate can be verified on our website.

Martin Tillander

**Director Product Certification** 

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.





#### Specification and performance

WFX Fire impregnated solid wood, for use in construction. The fire retardant is applied to the solid wood in a vacuum-pressure impregnation process. The name of the fire retardant is Woodsafe Exterior WFX.

Product / Wood species	Product code	Density (kg/m³)	Nominal thickness (mm)	Reaction to fire (Euroclass)	Note
WFX Heat modified Pine panel/ WFX Thermowood Pine panel (Pinus sylvestris)	08	450-600	21	B-s2, d0	3)
			>21	B-s3, d0	3)
WFX Heat Modified Spruce panel (Picea abies)	05. HM Spruce	400-500	18(9)	B-s1, d0	6), 8)
			>18(9)	B-s2, d0	
WFX Heat modified Spruce panel/ WFX Thermowood Spruce panel ( <i>Picea abies</i> )	04.1	400-500	18(9)	B-s2, d0	6)
			>18(9)	B-s3, d0	
WFX Heat modified Spruce panel open/		19	B-s2, d0		
WFX Thermowood Spruce panel open ( <i>Picea abies</i> )	04.2	400-500	>19	B-s3, d0	7)
WFX Heat modified Frake panel (Terminilia superba)	24	440-631	18	B-s1, d0	1)
			>18	B-s2, d0	
WFX Heat modified Ayous panel open (Triplochiton scleroxylon)	12	370-430	18	B-s2, d0	10)
			>18	B-s3, d0	
WFX Spruce panel (Picea abies)	27	392-566	18(9)	B-s1, d0	1)
			>18(9)	B-s2, d0	
WFX Spruce panel (Picea abies)	16. Spruce	460-500	18(9)	B-s2, d0	3)
			>18(9)	B-s3, d0	
WFX Pine panel (Pinus sylvestris)	16. Pine	500-570	18(9)	B-s2, d0	3)
			>18(9)	B-s3, d0	
WFX Western Red Cedar panel (Thuja plicata)	01	350-500	17,5 (10)	B-s1, d0	3)
			>17,5 (10)	B-s2, d0	
WFX Western Red Cedar panel (Thuja plicata)	21	320-360	18	B-s2, d0	1)
			>18	B-s3, d0	
WFX Western Red Cedar panel (Thuja plicata)	16. WRC	460-500	18	B-s2, d0	3)
			>18	B-s3, d0	

Certificate 0402-CPR-SC0260-15 | issue 10 | 2023-04-03



Product / Wood species	Product code	Density (kg/m³)	Nominal thickness (mm)	Reaction to fire (Euroclass)	Note
WFX Siberian larch panel (Larix sibirica)	25	567-825	20	B-s1, d0	1)
			>20	B-s2, d0	
WFX Siberian larch panel (Larix sibirica)	16. Larch	650-700	18(9)	B-s2, d0	3)
			>18(9)	B-s3, d0	
WFX Douglas fir panel/	22	23 449-746	18(9)	B-s1, d0	1)
WFX Oregon pine panel (Pseudotsuga menziessii)	23		>18(9)	B-s2, d0	
WFX Douglas fir panel/ WFX Oregon pine panel	16.	1 /1 /()-5 /() 1	18(9)	B-s2, d0	3)
(Pseudotsuga menziessii)	Douglas		>18(9)	B-s3, d0	
WFX Oak panel	26	479-868	19	B-s1, d0	- 2)
(Quercus robur)	20		>19	B-s2, d0	
WFX Sweet chestnut panel	22	514-775	22	B-s1, d0	- 2)
(Castanea Sativa)			>22	B-s2, d0	
WFX Nobelwood Radiata Pine panel	0.01.1	460-500	18	B-s2, d0	3)
(Pinus Radiata)	0.01.1		>18	B-s3, d0	
WFX Nobelwood Radiata Pine	0.01.2 460-5	460-500	18	B-s2, d0	- 5)
panel open (Pinus Radiata)		400-300	>18	B-s3, d0	
WFX Platowood Frake panel (Terminilia superba)	05.HM Frake	430-730	18	B-s1, d0	6), 8)
			>18	B-s2, d0	
WFX Platowood Frake panel Umbra, 2 x 70 g/m² (wet). (Terminilia superba)	13	450-550	18(9)	B-s1, d0	13)
			>18(9)	B-s2, d0	
WFX Platowood Poplar panel Umbra, 2 x 70 g/m² (wet).	19	390-490	18(9)	B-s1, d0	14)
(Poulus)			>18(9)	B-s2, d0	
WFX Platowood Poplar panel TEKNOSHIELD 4005-00-BASE T, 2 x 80 g/m² (wet). (Poulus)	11	380-440	18(9)	B-s1, d0	11)
			>18(9)	B-s2, d0	
WFX Accoya® Radiata Pine panel (Pinus Radiata)	02	510-620	17	B-s1, d0	4)
			>17	B-s2, d0	

Certificate 0402-CPR-SC0260-15 | issue 10 | 2023-04-03



Product / Wood species	Product code	Density (kg/m³)	Nominal thickness (mm)	Reaction to fire (Euroclass)	Note
WFX Accoya® Radiata Pine panel slat open	17	600-700	22	B-s1, d0	10)
(Pinus Radiata)			>22	B-s2, d0	
WFX Superwood Spruce panel TEKNOSHIELD 4005-00-BASE T,	09	310-380	21(9)	B-s2, d0	9)
2 x 80 g/m <sup>2</sup> (wet) (Picea abies)			>21(9)	B-s3, d0	
WFX Superwood Spruce slat open 45 x 45mm mounted onto	10	460-480	45	B-s2, d0	12)
Superwood spruce stud 33 x 70mm ( <i>Picea abies</i> )			>45	B-s2, d0	

#### Notes to tables above

- 1) This classification is valid for the following end use conditions: Any wood based substrate of Euroclass D-s2,d0 or better, or any substrate of Euroclasses A1 orA2-s1,d0, both with a density equal to or greater than 338 kg/m $^3$  and a thickness equal to or greater than 8 mm. Mechanically fixed, with or without an air gap.
- 2) This classification is valid for the following end use conditions: Any wood based substrate of Euroclass D-s2,d0 or better, or any substrate of Euroclasses A1 or A2-s1,d0, both with a density equal to or greater than  $338 \text{ kg/m}^3$  and a thickness equal to or greater than 8 mm. Mechanically fixed, with or without an air gap. Boards mounted horizontally.
- 3) This classification is valid for the following end use conditions: Gypsum plasterboard (paper faced) and any end use substrate of Euroclasses A1 or A2-s1,d0 at least 12 mm thick, having a density  $\geq$  525 kg/m<sup>3</sup>. Mechanically fixed, mounted with or without an air gap against the substrate. Horizontal mounting, with horizontal and vertical joints.
- 4) This classification is valid for the following end use conditions: Gypsum plasterboard (paper faced) and any end use substrate of Euroclasses A1 or A2-s1,d0 at least 12 mm thick, having a density  $\geq$  525 kg/m<sup>3</sup>. Mechanically fixed, mounted with or without an air gap against the substrate. Vertical mounting, with horizontal and vertical joints.
- 5) This classification is valid for the following end use conditions: Gypsum plasterboard (paper faced) and any end use substrate of Euroclasses A1 or A2-s1,d0 at least 12 mm thick, having a density  $\geq$  525 kg/m<sup>3</sup>. Mechanically fixed, vertically mounted panels with or without an air gap to the substrate. Void of 10 mm between the panels.
- 6) This classification is valid for the following end use conditions: Gypsum plasterboard (paper faced) and any end use substrate of Euroclasses A1 or A2-s1,d0 at least 12 mm thick, having a density  $\geq$  525 kg/m<sup>3</sup>. Mechanically fixed. Wood scantlings creating a void. Horizontal mounting, with horizontal and vertical joints.
- 7) This classification is valid for the following end use conditions: Gypsum plasterboard (paper faced) and any end use substrate of Euroclasses A1 or A2-s1,d0 at least 12 mm thick, having a density  $\geq$  525 kg/m<sup>3</sup>. Mechanically fixed. Wood scantlings creating a void. Vertical mounting with 10 mm gap between panels. With horizontal and vertical joints.

Certificate 0402-CPR-SC0260-15 | issue 10 | 2023-04-03

RISE Research Institutes of Sweden AB | Certification



- 8) The products are available with colour treatment Teknoshield, grey black, 80 g/m<sup>2</sup> (wet).
- 9) This classification is valid for the following end use conditions: Gypsum plasterboard (paper faced) and any end use substrate of Euroclasses A1 or A2-s1,d0 at least 12 mm thick, having a density ≥ 525 kg/m³. Mechanically fixed. Vertical or horizontal mounting. Horizontal and vertical joints. Wooden study creating an air-gap.
- 10) This classification is valid for the following end use conditions: Gypsum plasterboard (paper faced) and any end use substrate of Euroclasses A1 or A2-s1,d0 at least 12 mm thick, having a density  $\geq$  525 kg/m<sup>3</sup>. Mechanically fixed. Vertical mounting with 10 mm gap between panels. Horizontal joints. FR-treated wooden scantlings creating an air-gap.
- 11) This classification is valid for the following end use conditions: Gypsum plasterboard (paper faced) and any end use substrate of Euroclasses A1 or A2-s1,d0 at least 12 mm thick, having a density  $\geq$  525 kg/m³. Mechanically fixed. Vertical mounting. Horizontal joints. FR-treated wooden scantlings creating an air-gap.
- 12) This classification is valid for the following end use conditions: Any end use substrate of Euroclasses A1 or A2-s1,d0 at least 9 mm thick, having a density  $\geq$  652 kg/m³. Mechanically fixed. Vertical slats. Open façade with 90 mm separation between each slat. Horizontal joints. Superwood Spruce wood studs creating a void of 33 mm.
- 13) This classification is valid for the following end use conditions: Backing, behind substrate, of wood based substrates at least 10 mm thick  $\geq$  510 kg/m<sup>3</sup>. Any end use substrate of Euroclass A1 at least 20 mm thick, having a density  $\geq$  37.5 kg/m<sup>3</sup>. Mechanically fixed. Vertical or horizontal mounting. Horizontal and vertical joints. Fire impregnated scantlings creating a void  $\geq$ 40 mm.
- 14) This classification is valid for the following end use conditions: Substrate for end use conditions, insulation Kingspan Kooltherm K15C with 100 mm thickness. Mechanically fixed. Vertical or horizontal mounting. Horizontal and vertical joints. Fire impregnated scantlings creating 46 mm void.

Certificate 0402-CPR-SC0260-15 | issue 10 | 2023-04-03